Geophysical Research Abstracts, Vol. 7, 01981, 2005 SRef-ID: 1607-7962/gra/EGU05-A-01981 © European Geosciences Union 2005



## **Review on the Regulatory Guides of Geological Investigation for NPP Siting**

C. B. Im, T. M. Shim, M. Noh, H. Lee, and H. S. Choi

Dept. of Nuclear Safety Research, Korea Institute of Nuclear Safety, Daejeon, South Korea (K136icb@kins.re.kr / Fax: 82-42-868-0459 / Phone: 82-42-868-0175)

## Introduction

This paper reviews the regulatory guides of geological investigations applied to NPP (nuclear power plant) siting in U.S.A., Japan, China and IAEA (International Atomic Energy Agency), and recommends possible regulatory guides to the investigation ranges and depths for NPP siting in Korea, considering the specific geological data produced from recently performed multidisciplinary researches at and around Korean NPP sites. Korea has been adopting Appendix A to Subpart A of 10 CFR Part 100 "Seismic and Geologic Siting Criteria for Nuclear Power Plants" of the U.S.A.

Results and discussion: a possible guide for NPP siting in Korea

The ranges and depths of geological investigation for NPP siting are based on performing several steps of investigation with respect to the distance from the NPP site. The investigation can be categorized into four levels - 'regional', 'near regional', 'site vicinity' and 'the site', based on distance from the site and investigation degree of the detail.

'Regional' level of investigation (within a radius of about 150km from the reactor) should be defined all the regional tectonic structures and seismogenic sources that could affect on the safety of the projected NPP. Regarding the distance determination for the regionally geological investigation from the site, it is reasonable to consider the distance range enough to detect all possible seismogenic sources that could generate a considerable vibratory ground motion to the projected NPP sites.

'Near regional' level of investigation (within a radius of about 40km from the reactor) is to verify all the details of regional geological aspects of the region. Size of the area

for the investigation should be large enough to define all geological and structural units that may include or be related to the site in space or time.

'Site vicinity' level of investigation (within a radius of about 5km from the reactor) is to 'scan' any possible sources of permanent surface deformation at the site and define their distributions and characteristics in 3-D. This level of investigation should involve more detailed survey than information or results obtained by regional and near regional investigations, and include equally-spaced drilling operations, trench works and geophysical explorations.

'The site' level of investigation (within a radius of about 1km from the reactor) is to assure that the foundation of the site is sound and acceptable for NPP facilities. This level of investigation should provide engineering information of the foundation, and sufficient data to verify clearly that reactor and safety-related structures should not be constructed on the capable fault.

In addition, final guides of the distances and depths of geological investigations for NPP siting will be available through continuous review and feedback of further research results.

## References

U. CHWAE, et al., 1998, Reevaluation of design basis earthquake considering Yangsan Fault, Final report, Vol. 1-3, Korea Institute of Geoscience and Mineral resources, p. 1694.

C.B. Im, et al., 2003, Development of evaluation basis for the safety against earthquakes, Final study report, KINS/GR-255, Vol. 1 & 2, Korea Institute of Nuclear Safety, p. 1433.

Y.P. Seo, et al., 2003, Development of detailed evaluation techniques for safety of NPPs against earthquakes,  $2^{nd}$  year term report 01NS17, Korea Electric Power Research Institute, p. 472.

NARA, 1997, Code of Federal Regulation 10, Energy: part 100 - Reactor Site Criteria, the Office of the Federal Register National Archives and Records Administration, U.S.A.

US NRC, 1997a, Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motion, Regulatory Guide 1.165, U.S. Nuclear Regulatory Commission.

US NRC, 1997b, Standard Review Plan, NUREG-0800, Chap. 2.5.1 - 2.5.5, U.S. Nuclear Regulatory Commission.

Expert Review Association on Nuclear Reactor, 1978, Safety Review Plan on geological and ground features, Japan (in Japanese).

National Nuclear Safety Bureau, 1994, Problems on earthquakes in selecting of NPP sites, Nuclear Safety Regulation, HAF 0101(1), China (in Chinese).

IAEA, 1991, Safety Series: Earthquake and Associated Topics in Relation to Nuclear Power Plant Siting, Safety Series No. 50-SG-S1, Rev. 1, International Atomic Energy Agency, Vienna.